



## Certificate - Indoor Air Comfort - Gold

PureOne by URSA

Product

URSA Deutschland GmbH 04509 Delitzsch, Germany; URSA France S.A.S. 57506 St. Avold, France Manufacturer

The product has undergone a successful testing and evaluation program as specified for Eurofins Indoor Air Comfort Gold certification, version 2.3 (2011). This includes a VOC emission chamber test and an audit of the manufacturing site.

## Successful evaluation means:

- No carcinogenic substances were detectable above their limit values, including four CMR substances regulated in France.
- Formaldehyde was below the limit value of 10 µg/m³.
- Sum of VOC (TVOC) was below the limit values of 1000 μg/m³ after 3 days and 100 μg/m³ after 28 days. The product was classified A+for TVOC and A for single VOCs, according to French VOC regulation
- Sum of SVOC after 28 days was below the limit value of 20 µg/m³.
- Evaluation of individual VOC: R values were below the limit values of 1 for both German NIK and French LCI lists after 28 days. Sums of VOC without German NIK and of VOC without French LCI both were below 50 μg/m³.
- Quality management system and factory production control program at production site complied with the requirements.
- Therefore the product qualifies for the Indoor Air Comfort Gold label.

Validity of certificate: 01/07/2012

Certificate No.: 2011-IACG-021

Date:

01/07/2011

Director Certification Chemical Safety

General Manager

Eurofins Product Testing A/S Tel. +45 70 22 42 76

ProductTesting@eurofins.com www.product-testing.eurofins.com

Sampling, testing and evaluation were performed according to the standards ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1, EN 13419 in the latest versions.